
LAWRENCE SECONDARY SCHOOLS MASTERPLAN


(ADDITIONAL COLLATERAL)

This material is provided in response to questions received at the Nov. 28 School Board Meeting. A final deliverable, containing all masterplan studies and supporting material will be submitted prior to the January 9 Board Meeting

FSHS PARKING/PAVING UPGRADES




LHS COURTYARD UPGRADES



RESTROOM/SHOWER UPGRADES AT ALL SECONDARY SCHOOLS







Existing LHS locker room showers

Proposed solution for individual showers


Proposed Individual stalls at FSHS

INDIVIDUAL SHOWER / CHANGING STALLS


In secondary schools across the school district, locker rooms are equipped with "gang", or group, showers. Many students are uncomfortable showering in front of their peers, resulting in underutilized shower facilities. Replacing gang showers with individual shower stalls would provide the option for students to both change and shower within a private setting.


An allowance is included in the base cost for modifications to all secondary school shower facilities, and pending secondary school restrooms, to address student/faculty preference for private facilities.

SOUTH / SOUTHWEST UPGRADES













in-class student breakout adjacent classrooms

Provide learning pockets within corridors for casual study spaces and small-group collaboration zones





dining + study commons

Begin to populate the traditional cafeteria with soft seating and moveable white boards for students to utilize the space 7 periods a day











Transparency within media puts "learning on display"

Providing a variety of seating options allows students to feel independent by taking control of their learning environment; solutions accommodate both head's down and group study

SOUTH / SOUTHWEST – EXAMPLE SOLUTIONS
gouldevans

CONSTRUCTION PHASING









2nd Floor Classroom Renovation = #03



LHS – PHASING PLAN, SECOND FLOOR

MEP LIFE CYCLE ANALYSIS

ECM Name	Description
Baseline	Existing Building
ECM 1	Replace Water Cooled Chillers
ECM 2	Replace Steam Boilers and AHU Coils
ECM 3	VFD CHW Pumps
ECM 4	VFD HW Pumps
ECM 5	Take ECM's 1-4

Life Cycle Cost Analysis Global Parameters									
Project Name	Lawrence High Scho	ool							
Building Area	240,845	gross sg ft							
Basline Capacity	900	Tons cooling							
Analysis Duration	25	years							
Discount Rate	5.0%								
Inflation Rate	2.0%								
Escalation Rate	2.0%								
Total Escalation	4.0%								


MEP Replace	ment	t Cost	Sum	mary	Esc	alation Rate:	Inflation	Rate						
	Bas	seline		ECM 1	ECN	12	ECM	13	ECM 4			ECM 5		
Euipment Life Cycle (Years)	10		30		30)	2		20			0		
Equipment Replacement Cost	\$	-	\$	72,000	\$ 140,000		\$ 27,600		\$ 22,80	00	essin _{ii}	\$ 262,	400	
One-Time Costs	\$	-	\$	-	\$	-	\$	-	\$	9/10/	-	\$		-
Salvage Value	\$	-	\$	-	\$	-	\$	-	\$		-	\$		-
Replacement Cost per Ton	\$	-	\$	80	\$ 15		\$ 31			\$ 25			\$ 292	
Lifetime Equipment Cost	\$	-	\$	(42,000)	\$ 44,000		\$ 364,058		\$ 56,68	80		\$ 262,	400	
Net Replacement \$ Savings vs. Baseline	\$	-	\$	42,000	\$ (44,000)		\$ (364,058)	\$ (56,6	80)		\$ (262	,400)	

Building En	erç	gy Cost Su	ımı	nary	Escalation Rate:			nflation Rate				
	Baseline ECM 1				ECM 2			ECM 3	ECM 4			ECM 5
Annual Energy Cost per sq. ft.	\$	1.61	\$	1.52	\$	1.55	\$	1.59	\$	1.59	\$	1.44
Lifetime Energy Cost	\$	12,420,083	\$	11,725,793	\$	11,957,223	\$	12,265,797	\$	12,234,939	\$	11,077,789
Net Energy Cost Savings vs. Baseline	\$	_	\$	2,472,187	\$	1,648,125	\$	549,375	\$	659,250	\$	4,779,561


MEP Mainte	nar	nce Cost	Sun	In	flation Rate						
	Baseline			ECM 1		ECM 2		ECM 3	ECM 4	ECM 5	
Annual Maint. Cost per sq ft	\$	0.50	\$	0.50	\$	0.50	\$	0.50	\$ 0.50	\$	0.50
Lifetime Maint. Cost	\$	3,857,169	\$	3,857,169	\$	3,857,169	\$	3,857,169	\$ 3,857,169	\$	3,857,169
Net Maint. Cost Savings vs. Baseline	\$	-	\$	-	\$	-	\$	-	\$ 7-	\$	-

	25-year Life Cycle														
ECM#	Description		Description Building Energy Costs		MEP Replacement Costs		P Maintenance Costs	Total Lifetime Cost			et Savings vs. Base	Net Present Value (NPV)			
Baseline	Existing Building	\$	12,420,083	S		S	3,857,169	S	16,277,252	S	-	N/A			
ECM 1	Replace Water Cooled Chille	S	11,725,793	S	42,000	S	3,857,169	\$	15,624,962	S	652,290	\$303,913.07			
ECM 2	Replace Steam Boilers and A	S	11,957,223	S	44,000	S	3,857,169	\$	15,858,392	S	418,860	\$114,989.66			
ECM 3	VFD CHW Pumps	S	12,265,797	S	364,058	S	3,857,169	\$	16,487,023	S	(209,771)	(\$164,263.44			
ECM 4	VFD HW Pumps	\$	12,234,939	S	56,680	\$	3,857,169	\$	16,148,788	S	128,465	\$65,454.09			
ECM 5	Take ECM's 1-4	S	11,077,789	S	262,400	S	3,857,169	S	15,197,357	S	1,079,895	\$470,231.93			

Simple Payback (Years) for PRIORITY 2/3 MEP OPTION







LED Lighting Payback:

8 Years

Payback period based on first cost of LED system and energy and maintenance savings only. Assumes that the current lighting system does not need to be replaced.

City of Lawrence Energy Code - IECC 2015/ASHRAE 90.1 2013: Both codes require automatic daylight dimming in classrooms. If the lighting system needs to be replaced, the first cost of an LED system will be comparable to a new, dimmable fluorescent system.

Annual Energy Cost Savings

